


This document, together with the concepts and designs presented herein, is an instrument of service, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kinney-Horn and Associates, Inc. shall be without liability to Kinney-Horn and Associates, Inc.



CURRENT 2021 PAVEMENT CONDITION INDEX

Branch ID	Section ID	Branch Name	Surface Type	Section Area (SF)	Approx. Age at Inspection	Last Major Work Date	Last Inspection Date	Pavement Condition Index	PCI Category
AP	01	Apron	AC	49,140	1.9	9/15/2021	9/15/2021	100	Good
AP	02	Apron	AC	84,000	1.9	9/15/2021	9/15/2021	100	Good
RW04	02	Runway 04-22	AAC	271,200	10.4	7/3/2011	9/9/2021	79	Satisfactory
RW17	01	Runway 17-35	AAC	450,000	12.3	8/1/2009	9/9/2021	82	Satisfactory
TW	01	Taxiway	AAC	108,800	12.3	8/1/2009	9/9/2021	80	Satisfactory
TW	01A	Taxiway	AC	15,450	1.9	9/15/2021	9/15/2021	100	Good
TW	04	Taxiway	AAC	8,925	10.9	1/1/2011	9/9/2021	79	Satisfactory
TW	05	Taxiway	AC	12,075	1.9	9/15/2021	9/15/2021	100	Good
TW	06	Taxiway	AC	35,840	11.1	9/30/2010	9/9/2021	85	Satisfactory
TW	22	Taxiway	AC	12,166	11.1	9/30/2010	9/9/2021	75	Satisfactory

AIRFIELD PAVEMENT WORK HISTORY

1. AIP-001, 1985, REHABILITATE RUNWAY 4/22, TURNAROUNDS, APRON, AND CONNECTING TAXIWAY.
2. AIP-002, 1992, CONSTRUCT RUNWAY 16/34, CONNECTING AND ACCESS TAXIWAYS; APRON EXPANSION.
3. AIP-003, 1993, REHABILITATE RUNWAY (RW04:02) AND APRON, CONSTRUCT TAXIWAY (TW:05).
4. AIP-004, 2001, CRACK SEAL, FOG SEAL, AND REMARK ALL PAVEMENTS.
5. AIP-009-2007, CRACK SEAL, FOG SEAL, AND REMARK ALL PAVEMENTS [RE-BID AIP-008-2006].
6. AIP-010/011-2009, OVERLAY RUNWAY 16/34 (RW17:01) AND TAXIWAY (TW:01).
7. AIP-014-2011, OVERLAY RUNWAY 4/22 (RW04:02) AND TAXIWAY (TW:04); CONSTRUCT TAXIWAYS (TW:06, TW:22).
8. AIP 018-2019, CRACK SEAL, FOG SEAL, AND REMARK ALL PAVEMENTS.
9. AIP 019-2020, RECONSTRUCT APRONS (AP:01, AP:02) AND TAXIWAYS (TW:01A, TW:05).

Runway



RW04-02-44: L&T Cracking



RW17-01-55: Overview

Taxiway



TW04-01: L&T Cracking



TW22-01: Depression

Re-Inspection Report

MDT SASP 2021

Generated Date 12/28/2021

Page 1 of 10

Network: 3U3 **Name:** Bowman Field (Anaconda) Airport

Branch: AP **Name:** Apron **Use:** APRON **Area:** 133,140 SqFt

Section: 01 of 2 **From:** STA 0+00A **To:** STA 2+34A **Last Const.:** 9/15/2021

Surface: AC **Family:** DEFAULT **Zone:** ANAC **Category:** D **Rank:** P

Area: 49,140 SqFt **Length:** 234 Ft **Width:** 210 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** ACN **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 7/30/1992 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 9/15/2021 **Work Type:** Complete Reconstruction - AC **Code:** CR-AC **Is Major M&R:** True

Last Insp. Date: 10/9/2018 **TotalSamples:** 9 **Surveyed:** 4

Conditions: PCI: 37 **NOTE: *** Pre-Construction PCI *****

Inspection Comments:

Sample Number: 002 **Type:** R **Area:** 5460.00 SqFt **PCI:** 27

Sample Comments:

41	ALLIGATOR CR	M	97.50	SqFt
45	DEPRESSION	M	130.00	SqFt
48	L & T CR	L	94.00	Ft
48	L & T CR	M	253.00	Ft
48	L & T CR	H	6.00	Ft
52	RAVELING	L	5460.00	SqFt
57	WEATHERING	M	5460.00	SqFt

Sample Number: 004 **Type:** R **Area:** 5460.00 SqFt **PCI:** 37

Sample Comments:

45	DEPRESSION	L	28.30	SqFt
45	DEPRESSION	M	29.70	SqFt
48	L & T CR	L	122.00	Ft
48	L & T CR	M	353.00	Ft
48	L & T CR	H	14.00	Ft
50	PATCHING	L	10.60	SqFt
50	PATCHING	M	5.30	SqFt
52	RAVELING	L	5460.00	SqFt
57	WEATHERING	M	5460.00	SqFt

Sample Number: 006 **Type:** R **Area:** 5460.00 SqFt **PCI:** 47

Sample Comments:

45	DEPRESSION	M	14.00	SqFt
48	L & T CR	L	203.00	Ft
48	L & T CR	M	136.00	Ft
48	L & T CR	H	4.00	Ft
50	PATCHING	L	.40	SqFt
52	RAVELING	L	5460.00	SqFt
57	WEATHERING	M	5460.00	SqFt

Sample Number: 008 **Type:** R **Area:** 5460.00 SqFt **PCI:** 37

Sample Comments:

41	ALLIGATOR CR	M	10.00	SqFt
45	DEPRESSION	M	10.00	SqFt
48	L & T CR	L	132.00	Ft
48	L & T CR	M	328.00	Ft
48	L & T CR	H	10.00	Ft
50	PATCHING	M	5.30	SqFt
52	RAVELING	L	5460.00	SqFt
57	WEATHERING	M	5460.00	SqFt

Network: 3U3 **Name:** Bowman Field (Anaconda) Airport

Branch: AP **Name:** Apron **Use:** APRON **Area:** 133,140 SqFt

Section: 02 of 2 **From:** STA 2+34A **To:** STA 6+34A **Last Const.:** 9/15/2021

Surface: AC **Family:** DEFAULT **Zone:** ANAC **Category:** D **Rank:** P

Area: 84,000 SqFt **Length:** 400 Ft **Width:** 210 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** ACN **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 7/30/1993 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 9/15/2021 **Work Type:** Complete Reconstruction - AC **Code:** CR-AC **Is Major M&R:** True

Last Insp. Date: 10/9/2018 **TotalSamples:** 17 **Surveyed:** 5

Conditions: PCI: 47 **NOTE: *** Pre-Construction PCI *****

Inspection Comments:

Sample Number: 001 **Type:** R **Area:** 4970.00 SqFt **PCI:** 46

Sample Comments:

45 DEPRESSION L 117.30 SqFt
48 L & T CR L 109.00 Ft
48 L & T CR M 322.00 Ft
48 L & T CR H 8.00 Ft
50 PATCHING L 17.40 SqFt
50 PATCHING M 2.60 SqFt
57 WEATHERING M 4970.00 SqFt

Sample Number: 003 **Type:** R **Area:** 4970.00 SqFt **PCI:** 49

Sample Comments:

45 DEPRESSION L 32.00 SqFt
45 DEPRESSION M 48.30 SqFt
48 L & T CR L 217.00 Ft
48 L & T CR M 263.00 Ft
48 L & T CR H 8.00 Ft
57 WEATHERING M 4970.00 SqFt

Sample Number: 007 **Type:** R **Area:** 4970.00 SqFt **PCI:** 48

Sample Comments:

45 DEPRESSION L 67.30 SqFt
48 L & T CR L 103.00 Ft
48 L & T CR M 318.00 Ft
48 L & T CR H 6.00 Ft
57 WEATHERING M 4970.00 SqFt

Sample Number: 009 **Type:** R **Area:** 4970.00 SqFt **PCI:** 50

Sample Comments:

48 L & T CR L 104.00 Ft
48 L & T CR M 363.00 Ft
48 L & T CR H 10.00 Ft
57 WEATHERING M 4970.00 SqFt

Sample Number: 013 **Type:** R **Area:** 4970.00 SqFt **PCI:** 44

Sample Comments:

45 DEPRESSION M 75.00 SqFt
48 L & T CR L 56.00 Ft
48 L & T CR M 307.00 Ft
48 L & T CR H 12.00 Ft
50 PATCHING M 168.00 SqFt
57 WEATHERING M 4970.00 SqFt

Network:	3U3	Name:	Bowman Field (Anaconda) Airport						
Branch:	RW04	Name:	Runway 04-22	Use:	RUNWAY	Area:	271,200 SqFt		
Section:	02	of	1	From:	Sta 0+00 RWY 4/22	To:	STA 45+20 RWY 4/22	Last Const.:	7/3/2011
Surface:	AAC	Family:	DEFAULT	Zone:	ANAC	Category:	E	Rank:	P
Area:	271,200 SqFt	Length:	4,520 Ft	Width:	60 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACR	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	7/31/1993	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	7/3/2011	Work Type:	Overlay - AC Structural		Code:	OL-AS	Is Major M&R:	True	
Work Date:	1/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Work Date:	1/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Last Insp. Date:	9/9/2021	TotalSamples:	54	Surveyed:	7				
Conditions:	PCI: 79								
Inspection Comments:									
Sample Number:	09	Type:	R	Area:	4800.00 SqFt	PCI:	83		
Sample Comments:									
48	L & T CR	L	190.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	16	Type:	R	Area:	4800.00 SqFt	PCI:	82		
Sample Comments:									
48	L & T CR	L	202.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	23	Type:	R	Area:	4800.00 SqFt	PCI:	74		
Sample Comments:									
48	L & T CR	L	271.00	Ft					
48	L & T CR	M	13.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	30	Type:	R	Area:	4800.00 SqFt	PCI:	75		
Sample Comments:									
48	L & T CR	L	235.00	Ft					
48	L & T CR	M	14.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	37	Type:	R	Area:	4800.00 SqFt	PCI:	74		
Sample Comments:									
48	L & T CR	L	268.00	Ft					
48	L & T CR	M	10.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	44	Type:	R	Area:	4800.00 SqFt	PCI:	76		
Sample Comments:									
48	L & T CR	L	226.00	Ft					
48	L & T CR	M	18.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	55	Type:	R	Area:	4800.00 SqFt	PCI:	88		
Sample Comments:									
48	L & T CR	L	91.00	Ft					
57	WEATHERING	L	4800.00	SqFt					

Network:	3U3		Name:	Bowman Field (Anaconda) Airport						
Branch:	RW17	Name:	Runway 17-35	Use:	RUNWAY	Area:	450,000 SqFt			
Section:	01	of	1	From:	Sta 0+00 RWY 16/34	To:	STA 60+00 RWY 16/34	Last Const.:	8/1/2009	
Surface:	AAC	Family:	DEFAULT	Zone:	ANAC	Category:	E	Rank:	P	
Area:	450,000 SqFt	Length:	6,000 Ft	Width:	75 Ft					
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:		Street Type:	ACR	Grade:	0	Lanes:	0			
Section Comments:										
Work Date:	7/31/1992	Work Type:	New Construction - Initial			Code:	NU-IN	Is Major M&R:	True	
Work Date:	8/1/2009	Work Type:	Overlay - AC Structural			Code:	OL-AS	Is Major M&R:	True	
Work Date:	1/1/2019	Work Type:	Crack Sealing - AC			Code:	CS-AC	Is Major M&R:	False	
Work Date:	1/1/2019	Work Type:	Surface Seal			Code:	SS-LO	Is Major M&R:	False	
Last Insp. Date:	9/9/2021	TotalSamples:	98	Surveyed:	7					
Conditions:	PCI:	82								
Inspection Comments:										
Sample Number:	07	Type:	R	Area:	4875.00 SqFt	PCI:	79			
Sample Comments:										
48	L & T CR	L	76.00	Ft						
48	L & T CR	M	47.00	Ft						
57	WEATHERING	L	4875.00	SqFt						
Sample Number:	23	Type:	R	Area:	4875.00 SqFt	PCI:	89			
Sample Comments:										
48	L & T CR	L	72.00	Ft						
57	WEATHERING	L	4875.00	SqFt						
Sample Number:	39	Type:	R	Area:	4875.00 SqFt	PCI:	85			
Sample Comments:										
48	L & T CR	L	147.00	Ft						
57	WEATHERING	L	4875.00	SqFt						
Sample Number:	55	Type:	R	Area:	4875.00 SqFt	PCI:	80			
Sample Comments:										
48	L & T CR	L	171.00	Ft						
48	L & T CR	M	4.00	Ft						
57	WEATHERING	L	4875.00	SqFt						
Sample Number:	71	Type:	R	Area:	4875.00 SqFt	PCI:	76			
Sample Comments:										
48	L & T CR	L	243.00	Ft						
48	L & T CR	M	6.00	Ft						
57	WEATHERING	L	4875.00	SqFt						
Sample Number:	87	Type:	R	Area:	4875.00 SqFt	PCI:	76			
Sample Comments:										
48	L & T CR	L	107.00	Ft						
48	L & T CR	M	80.00	Ft						
57	WEATHERING	L	4875.00	SqFt						
Sample Number:	98	Type:	R	Area:	4875.00 SqFt	PCI:	88			
Sample Comments:										
48	L & T CR	L	89.00	Ft						
57	WEATHERING	L	4875.00	SqFt						

Network:	3U3		Name:	Bowman Field (Anaconda) Airport					
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	193,256 SqFt		
Section:	01	of 6	From:	RWY 4/22	To:	RWY 34/16, and Hangars	Last Const.: 8/1/2009		
Surface:	AAC	Family:	DEFAULT	Zone:	ANAC	Category:	E	Rank:	P
Area:	108,800 SqFt	Length:	4,352 Ft	Width:	25 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACR	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	7/31/1992	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	8/1/2009	Work Type:	Overlay - AC Structural		Code:	OL-AS	Is Major M&R:	True	
Work Date:	1/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Work Date:	1/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Last Insp. Date:	9/9/2021	TotalSamples:	20	Surveyed:	5				
Conditions:	PCI:	80							
Inspection Comments:									
Sample Number:	02	Type:	R	Area:	5000.00 SqFt	PCI:	80		
Sample Comments:									
48	L & T CR	L	264.00	Ft					
57	WEATHERING	L	5000.00	SqFt					
Sample Number:	07	Type:	R	Area:	5000.00 SqFt	PCI:	79		
Sample Comments:									
48	L & T CR	L	269.00	Ft					
57	WEATHERING	L	5000.00	SqFt					
Sample Number:	12	Type:	R	Area:	2825.00 SqFt	PCI:	78		
Sample Comments:									
48	L & T CR	L	111.00	Ft					
48	L & T CR	M	8.00	Ft					
57	WEATHERING	L	2825.00	SqFt					
Sample Number:	15	Type:	R	Area:	4960.00 SqFt	PCI:	82		
Sample Comments:									
48	L & T CR	L	217.00	Ft					
57	WEATHERING	L	4960.00	SqFt					
Sample Number:	19	Type:	R	Area:	4400.00 SqFt	PCI:	80		
Sample Comments:									
48	L & T CR	L	155.00	Ft					
48	L & T CR	M	5.00	Ft					
57	WEATHERING	L	4400.00	SqFt					

Network: 3U3 **Name:** Bowman Field (Anaconda) Airport

Branch: TW **Name:** Taxiway **Use:** TAXIWAY **Area:** 193,256 SqFt

Section: 01A of 6 **From:** Southeast corner **To:** A-1 **Last Const.:** 9/15/2021

Surface: AC **Family:** DEFAULT **Zone:** ANAC **Category:** D **Rank:** P

Area: 15,450 SqFt **Length:** 618 Ft **Width:** 25 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** ACR **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 8/1/1992 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 9/15/2021 **Work Type:** Complete Reconstruction - AC **Code:** CR-AC **Is Major M&R:** True

Last Insp. Date: 10/9/2018 **Total Samples:** 4 **Surveyed:** 3

Conditions: PCI: 62 **NOTE: *** Pre-Construction PCI *****

Inspection Comments:

Sample Number: 001 **Type:** R **Area:** 4500.00 SqFt **PCI:** 61

Sample Comments:

48 L & T CR L 18.00 Ft
48 L & T CR M 4.00 Ft
52 RAVELING L 4500.00 SqFt
57 WEATHERING M 4500.00 SqFt

Sample Number: 002 **Type:** R **Area:** 4500.00 SqFt **PCI:** 62

Sample Comments:

48 L & T CR L 16.00 Ft
48 L & T CR M 57.00 Ft
50 PATCHING L .40 SqFt
52 RAVELING L 4500.00 SqFt
57 WEATHERING M 4500.00 SqFt

Sample Number: 004 **Type:** R **Area:** 4500.00 SqFt **PCI:** 63

Sample Comments:

45 DEPRESSION L .02 SqFt
48 L & T CR L 16.00 Ft
48 L & T CR M 44.00 Ft
52 RAVELING L 4500.00 SqFt
57 WEATHERING M 4500.00 SqFt

Network:	3U3	Name:	Bowman Field (Anaconda) Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	193,256 SqFt		
Section:	04	of 6	From:	RWY 4-22	To:	APRON	Last Const.:	1/1/2011	
Surface:	AAC	Family:	DEFAULT	Zone:	ANAC	Category:	D	Rank:	P
Area:	8,925 SqFt	Length:	255 Ft	Width:	35 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	ACR	Grade:	0	Lanes:	0			
Section Comments:									
Work Date:	7/31/1985	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	1/1/2011	Work Type:	2 in overlay		Code:	OL_2	Is Major M&R:	True	
Work Date:	1/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Work Date:	1/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Last Insp. Date:	9/9/2021	TotalSamples:	2	Surveyed:	2				
Conditions:	PCI: 79								
Inspection Comments:									
Sample Number:	01	Type:	R	Area:	4200.00 SqFt	PCI:	78		
Sample Comments:									
48	L & T CR	L	17.00	Ft					
48	L & T CR	M	50.00	Ft					
57	WEATHERING	L	3990.00	SqFt					
57	WEATHERING	M	210.00	SqFt					
Sample Number:	02	Type:	R	Area:	2625.00 SqFt	PCI:	81		
Sample Comments:									
45	DEPRESSION	L	48.00	SqFt					
57	WEATHERING	L	2494.00	SqFt					
57	WEATHERING	M	131.00	SqFt					

Network: 3U3 **Name:** Bowman Field (Anaconda) Airport

Branch: TW **Name:** Taxiway **Use:** TAXIWAY **Area:** 193,256 SqFt

Section: 05 of 6 **From:** Apron to Hangars **To:** **Last Const.:** 9/15/2021

Surface: AC **Family:** DEFAULT **Zone:** ANAC **Category:** D **Rank:** P

Area: 12,075 SqFt **Length:** 345 Ft **Width:** 35 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** ACR **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 7/31/1993 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 9/15/2021 **Work Type:** Complete Reconstruction - AC **Code:** CR-AC **Is Major M&R:** True

Last Insp. Date: 10/9/2018 **TotalSamples:** 3 **Surveyed:** 3

Conditions: PCI: 51 **NOTE: *** Pre-Construction PCI *****

Inspection Comments:

Sample Number: 1 **Type:** R **Area:** 4025.00 SqFt **PCI:** 48

Sample Comments:

45 DEPRESSION L .05 SqFt
45 DEPRESSION M 24.70 SqFt
48 L & T CR L 74.00 Ft
48 L & T CR M 248.00 Ft
48 L & T CR H 5.00 Ft
50 PATCHING L .10 SqFt
57 WEATHERING M 4025.00 SqFt

Sample Number: 2 **Type:** R **Area:** 4025.00 SqFt **PCI:** 53

Sample Comments:

45 DEPRESSION M 12.40 SqFt
48 L & T CR L 81.00 Ft
48 L & T CR M 194.00 Ft
48 L & T CR H 5.00 Ft
50 PATCHING L .50 SqFt
57 WEATHERING M 4025.00 SqFt

Sample Number: 3 **Type:** R **Area:** 4025.00 SqFt **PCI:** 54

Sample Comments:

45 DEPRESSION M 24.70 SqFt
48 L & T CR L 102.00 Ft
48 L & T CR M 211.00 Ft
48 L & T CR H 8.00 Ft
57 WEATHERING M 4025.00 SqFt

Network:	3U3	Name:	Bowman Field (Anaconda) Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	193,256 SqFt		
Section:	06	of 6	From:	RW 34	To:	RW 4	Last Const.:	9/30/2010	
Surface:	AC	Family:	DEFAULT	Zone:	ANAC	Category:	E	Rank:	P
Area:	35,840 SqFt	Length:	1,024 Ft	Width:	35 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	ACR	Grade:	0	Lanes:	0			
Section Comments:									
Work Date:	9/30/2010	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	1/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Work Date:	1/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Last Insp. Date:	9/9/2021	TotalSamples:	7	Surveyed:	4				
Conditions:	PCI: 85								
Inspection Comments:									
Sample Number:	01	Type:	R	Area:	4900.00 SqFt	PCI:	88		
Sample Comments:									
48	L & T CR	L	2.00	Ft					
48	L & T CR	M	15.00	Ft					
57	WEATHERING	L	4900.00	SqFt					
Sample Number:	02	Type:	R	Area:	4900.00 SqFt	PCI:	82		
Sample Comments:									
48	L & T CR	L	7.00	Ft					
48	L & T CR	M	60.00	Ft					
57	WEATHERING	L	4900.00	SqFt					
Sample Number:	03	Type:	R	Area:	4375.00 SqFt	PCI:	86		
Sample Comments:									
48	L & T CR	L	21.00	Ft					
48	L & T CR	M	3.00	Ft					
57	WEATHERING	L	4375.00	SqFt					
Sample Number:	07	Type:	R	Area:	3640.00 SqFt	PCI:	82		
Sample Comments:									
48	L & T CR	L	10.00	Ft					
48	L & T CR	M	13.00	Ft					
57	WEATHERING	L	3458.00	SqFt					
57	WEATHERING	M	182.00	SqFt					

Network: 3U3 **Name:** Bowman Field (Anaconda) Airport

Branch: TW **Name:** Taxiway **Use:** TAXIWAY **Area:** 193,256 SqFt

Section: 22 of 6 **From:** RW 22 **To:** END **Last Const.:** 9/30/2010

Surface: AC **Family:** DEFAULT **Zone:** ANAC **Category:** D **Rank:** P

Area: 12,166 SqFt **Length:** 154 Ft **Width:** 79 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** ACR **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 9/30/2010 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 1/1/2019 **Work Type:** Surface Seal **Code:** SS-LO **Is Major M&R:** False

Work Date: 1/1/2019 **Work Type:** Crack Sealing - AC **Code:** CS-AC **Is Major M&R:** False

Last Insp. Date: 9/9/2021 **TotalSamples:** 2 **Surveyed:** 2

Conditions: PCI: 75

Inspection Comments:

Sample Number: 01 **Type:** R **Area:** 6083.00 SqFt **PCI:** 69

Sample Comments:

45 DEPRESSION L 210.00 SqFt

45 DEPRESSION M 35.00 SqFt

57 WEATHERING L 5475.00 SqFt

57 WEATHERING M 608.00 SqFt

Sample Number: 02 **Type:** R **Area:** 6083.00 SqFt **PCI:** 81

Sample Comments:

45 DEPRESSION L 30.00 SqFt

48 L & T CR L 53.00 Ft

57 WEATHERING L 5475.00 SqFt

57 WEATHERING M 608.00 SqFt