

616.03, Plastic and Steel Conduit (Electrical)

Qualification Requests

On the laboratory test report that is sent in with the request, the test data must show that the material is in compliance with the Material requirements.

Qualification Samples

The requirements for samples that are received for QPL prequalification are as follows.

- ◆ The producer will submit a minimum of two samples (3 feet long) for each type of conduit to be considered along with test results from an independent laboratory.
- ◆ MDT will test each sample according to the tests outlined in subsection "703.02 Conduit". The material will be rejected if the material does not meet the requirements.

Material Requirements

Requirements may be found in the Standard Specifications for Road and Bridge Construction subsection 703.02, the Supplemental specifications to Montana Standard Specifications subsection 703.02 or contract Special Provisions.