

**PROPOSED DRAFT
MAY 2015**

106.05 FIELD LABORATORY

The Department will furnish all field offices, laboratories and cure boxes.

Deleted: and

Furnish and install electrical power to field offices and laboratories as directed:

- A continuous 200-ampere, 220 to 230 volt, single phase, 60-hertz power supply using a four wire connector; or
- A 110 to 120 volt alternating current of sufficient capacity.

Have the source connected by a Montana licensed electrician.

Furnish a potable water supply to operate all testing equipment for the offices and laboratories.

Notify the Project Manager at least 2 business days prior to producing material to be tested in the field laboratory or cured in the cure boxes. Do not begin production until the test trailer or cure box is fully operational.

No additional payment will be made for providing power and water to the field office, laboratories or cure boxes. Include these costs in the other items on the project.

Deleted: and

COMMENTS

1. I feel it's necessary to add "cure boxes" in each instance we are referring to the "list" of applicable situations. "Furnish and install electrical power to field offices, and laboratories, and cure boxes as directed:"

Response: Agreed.

**FINAL
EFFECTIVE AUGUST 6, 2015**

106.05 FIELD LABORATORY

The Department will furnish all field offices, laboratories and cure boxes.

Furnish and install electrical power as directed:

- A continuous 200-ampere, 220 to 230 volt, single phase, 60-hertz power supply using a four wire connector; or
- A 110 to 120 volt alternating current of sufficient capacity.

Have the source connected by a Montana licensed electrician.

Furnish a potable water supply to operate all testing equipment for the offices and laboratories.

Notify the Project Manager at least 2 business days prior to producing material to be tested in the field laboratory or cured in the cure boxes. Do not begin production until the test trailer or cure box is fully operational.

No additional payment will be made for providing power and water to the field offices, laboratories or cure boxes. Include these costs in the other items on the project.