

551.02.13, Ground Granulated Blast Furnace Slag

Qualification Requests

Provide the Department with a completed request form and a laboratory test report showing that the material is in compliance with the Department's material requirements.

Material Requirements

Provide materials meeting the requirements of the Standard Specifications for Road and Bridge Construction subsection 551.02.13 Ground Granulated Blast Furnace Slag modified as necessary to address corresponding supplemental specifications, or contract Special Provisions.

Qualification Procedures

Submit two samples in 250 ml plastic bottles (i.e. Nalgene or similar) for each type of Ground Granulated Blast Furnace Slag to be considered along with test results from an independent laboratory.

The Department will test each sample according to the tests outlined in subsection "551.02.13 Ground Granulated Blast Furnace Slag". Materials not meeting the requirements will be rejected. Materials meeting the requirements will be placed on the QPL.

Submit each type of Ground Granulated Blast Furnace Slag every 6 months for testing to remain on the QPL.