



This document, together with the concepts and designs presented herein, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kinney-Horn and Associates, Inc. shall be without liability to Kinney-Horn and Associates, Inc.



CURRENT 2021 PAVEMENT CONDITION INDEX

Branch ID	Section ID	Branch Name	Surface Type	Section Area (SF)	Approx. Age at Inspection	Last Major Work Date	Last Inspection Date	Pavement Condition Index	PCI Category
AP	03	Apron	AC	92,250	27.2	9/30/1994	9/10/2021	80	Satisfactory
AP	04	Apron	AC	78,200	19.3	8/1/2002	9/10/2021	73	Satisfactory
AP	11	Apron	AAC	193,569	13.3	8/1/2008	9/10/2021	84	Satisfactory
RW04	21	Runway 04-22	AAC	178,680	12.3	8/1/2009	9/10/2021	82	Satisfactory
RW17	03	Runway 17-35	AC	467,400	23.2	9/20/1998	9/10/2021	55	Poor
RW17	04	Runway 17-35	AC	58,500	23.2	9/29/1998	9/10/2021	56	Fair
TW	02	Taxiway	AC	16,510	27.2	9/30/1994	9/10/2021	77	Satisfactory
TW	03	Taxiway	AC	212,275	23.2	9/20/1998	9/10/2021	52	Poor
TW	04	Taxiway	AC	26,575	19.3	8/1/2002	9/10/2021	80	Satisfactory
TW	05	Taxiway	AC	33,288	12.3	8/1/2009	9/10/2021	82	Satisfactory

AIRFIELD PAVEMENT WORK HISTORY

1. P-207 IS RECLAIMED ASPHALT BASE COURSE (1½" MINUS), PULVERIZED IN PLACE, MIXED WITH AGGREGATE BASE.
2. AIP-002-1988, NEW AND OVERLAY
3. AIP-003-1988, NEW
4. AIP-004-1994, EXPAND APRON; CONSTRUCT ACCESS TAXIWAY.
5. AIP-005-1998, FULL DEPTH PULVERIZE AND RECONSTRUCT RUNWAY 16/34 AND CROSSWIND TRANSITION; CONSTRUCT PARALLEL AND CONNECTING TAXIWAYS.
6. AIP-006-2002, EXPAND APRON (AP:04); CONSTRUCT TAXIWAY (TW:04); CRACK SEAL, FOG SEAL, REMARK RUNWAY (RW04:03).
7. AIP-009-2009, RECONSTRUCT RUNWAY 4/22 (RW04:21) AND APRON (AP:11); CONSTRUCT TAXIWAY (TW:05); CONSTRUCT RUNWAY BLAST PAD (RW04:04A); MILL AND OVERLAY APRON (AP:03) AND TAXILANES (T-2); CRACK SEAL, FOG SEAL, AND REMARK RUNWAY 17/35 (RW17:03,RW17:04), TAXIWAYS (TW:03,TW:04) AND APRON (AP:04); REMOVE TAXIWAY (TW:01) AND APRON (AP:02).
8. AIP-011-2014, CONSTRUCT TAXIWAY FILLETS (EXEMPT); CRACK SEAL, FOG SEAL, AND REMARK ALL PAVEMENTS.
9. AIP 013-2019 CRACK SEAL, FOG SEAL, AND REMARK ALL PAVEMENTS.

Runway



RW17-03-02: Alligator Cracking



RW17-03-30: Rutting



RW17-03-86: L&T Cracking



RW17-04-01: Bleeding

Taxiway



TW03-20: Depression



TW03-28: Rutting

Apron



AP03-15: Overview



AP04-09: L&T Cracking

Re-Inspection Report

MDT SASP 2021

Generated Date 12/6/2021

Page 1 of 12

Network: DLN **Name:** Dillon Airport

Branch: AP **Name:** Apron **Use:** APRON **Area:** 364,019 SqFt

Section: 03 of 3 **From:** NORTH APRON **To:** **Last Const.:** 9/30/1994

Surface: AC **Family:** DEFAULT **Zone:** DILL **Category:** D **Rank:** P

Area: 92,250 SqFt **Length:** 450 Ft **Width:** 205 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** ACN **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 9/30/1994 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 1/1/2019 **Work Type:** Crack Sealing - AC **Code:** CS-AC **Is Major M&R:** False

Work Date: 1/1/2019 **Work Type:** Surface Seal **Code:** SS-LO **Is Major M&R:** False

Last Insp. Date: 9/10/2021 **Total Samples:** 18 **Surveyed:** 5

Conditions: PCI: 80

Inspection Comments:

Sample Number: 01 **Type:** R **Area:** 5100.00 SqFt **PCI:** 83

Sample Comments:

45	DEPRESSION	L	6.00	SqFt
48	L & T CR	L	93.00	Ft
57	WEATHERING	L	4335.00	SqFt
57	WEATHERING	M	765.00	SqFt

Sample Number: 03 **Type:** R **Area:** 5100.00 SqFt **PCI:** 82

Sample Comments:

48	L & T CR	L	42.00	Ft
57	WEATHERING	L	4080.00	SqFt
57	WEATHERING	M	1020.00	SqFt

Sample Number: 09 **Type:** R **Area:** 5100.00 SqFt **PCI:** 81

Sample Comments:

48	L & T CR	L	61.00	Ft
57	WEATHERING	L	4080.00	SqFt
57	WEATHERING	M	1020.00	SqFt

Sample Number: 15 **Type:** R **Area:** 5100.00 SqFt **PCI:** 81

Sample Comments:

48	L & T CR	L	140.00	Ft
57	WEATHERING	L	4080.00	SqFt
57	WEATHERING	M	1020.00	SqFt

Sample Number: 18 **Type:** R **Area:** 5100.00 SqFt **PCI:** 76

Sample Comments:

48	L & T CR	L	73.00	Ft
48	L & T CR	M	10.00	Ft
57	WEATHERING	L	4080.00	SqFt
57	WEATHERING	M	1020.00	SqFt

Network:	DLN	Name:	Dillon Airport						
Branch:	AP	Name:	Apron	Use:	APRON	Area:	364,019 SqFt		
Section:	04	of 3	From:	A-3 & T-3	To:	HANGARS	Last Const.:	8/1/2002	
Surface:	AC	Family:	DEFAULT	Zone:	DILL	Category:	G	Rank:	P
Area:	78,200 SqFt	Length:	460 Ft	Width:	170 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	ACA	Grade:	0	Lanes:	0			
Section Comments:									
Work Date:	8/1/2002	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	1/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Work Date:	1/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Last Insp. Date:	9/10/2021	TotalSamples:	15	Surveyed:	5				
Conditions:	PCI:	73							
Inspection Comments:									
Sample Number:	03	Type:	R	Area:	5198.00 SqFt	PCI:	67		
Sample Comments:									
48	L & T CR	L	726.00	Ft					
57	WEATHERING	L	5198.00	SqFt					
Sample Number:	04	Type:	R	Area:	5198.00 SqFt	PCI:	78		
Sample Comments:									
48	L & T CR	L	324.00	Ft					
57	WEATHERING	L	5198.00	SqFt					
Sample Number:	09	Type:	R	Area:	5198.00 SqFt	PCI:	62		
Sample Comments:									
48	L & T CR	L	731.00	Ft					
48	L & T CR	M	40.00	Ft					
57	WEATHERING	L	5198.00	SqFt					
Sample Number:	10	Type:	R	Area:	5198.00 SqFt	PCI:	73		
Sample Comments:									
48	L & T CR	L	478.00	Ft					
57	WEATHERING	L	5198.00	SqFt					
Sample Number:	13	Type:	R	Area:	5198.00 SqFt	PCI:	84		
Sample Comments:									
48	L & T CR	L	180.00	Ft					
57	WEATHERING	L	5198.00	SqFt					

Network:	DLN	Name:	Dillon Airport						
Branch:	AP	Name:	Apron	Use:	APRON	Area:	364,019 SqFt		
Section:	11	of 3	From:	WEST APRON	To:	OFF T-5	Last Const.:	8/1/2008	
Surface:	AAC	Family:	DEFAULT	Zone:	DILL	Category:	D	Rank:	P
Area:	193,569 SqFt	Length:	3,871 Ft	Width:	50 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACN	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/1/2008	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	1/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Work Date:	1/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Last Insp. Date:	9/10/2021	TotalSamples:	11	Surveyed:	4				
Conditions:	PCI: 84								
Inspection Comments:									
Sample Number:	01	Type:	R	Area:	4380.00 SqFt	PCI:	78		
Sample Comments:									
45	DEPRESSION	L	48.00	SqFt					
48	L & T CR	L	112.00	Ft					
57	WEATHERING	L	4161.00	SqFt					
57	WEATHERING	M	219.00	SqFt					
Sample Number:	03	Type:	R	Area:	4380.00 SqFt	PCI:	79		
Sample Comments:									
45	DEPRESSION	L	10.00	SqFt					
48	L & T CR	L	42.00	Ft					
50	PATCHING	L	104.00	SqFt					
57	WEATHERING	L	4062.00	SqFt					
57	WEATHERING	M	214.00	SqFt					
Sample Number:	07	Type:	R	Area:	4956.00 SqFt	PCI:	92		
Sample Comments:									
48	L & T CR	L	40.00	Ft					
57	WEATHERING	M	248.00	SqFt					
Sample Number:	09	Type:	R	Area:	4956.00 SqFt	PCI:	86		
Sample Comments:									
48	L & T CR	L	63.00	Ft					
57	WEATHERING	L	4708.00	SqFt					
57	WEATHERING	M	248.00	SqFt					

Network:	DLN	Name:	Dillon Airport						
Branch:	RW04	Name:	Runway 04-22	Use:	RUNWAY	Area:	178,680 SqFt		
Section:	21	of	1	From:	RWY 4/22 STA. 12+00	To:	RWY 4/22 STA. 48+00	Last Const.:	8/1/2009
Surface:	AAC	Family:	DEFAULT	Zone:	DILL	Category:	D	Rank:	P
Area:	178,680 SqFt	Length:	2,978 Ft	Width:	60 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:		Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/1/2009	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	1/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Work Date:	1/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Last Insp. Date:	9/10/2021	TotalSamples:	40	Surveyed:	7				
Conditions:	PCI:	82							
Inspection Comments:									
Sample Number:	02	Type:	R	Area:	3440.00 SqFt	PCI:	89		
Sample Comments:									
48	L & T CR	L	40.00	Ft					
57	WEATHERING	L	3440.00	SqFt					
Sample Number:	09	Type:	R	Area:	4800.00 SqFt	PCI:	81		
Sample Comments:									
48	L & T CR	L	218.00	Ft					
57	WEATHERING	L	2880.00	SqFt					
Sample Number:	14	Type:	R	Area:	4800.00 SqFt	PCI:	75		
Sample Comments:									
48	L & T CR	L	252.00	Ft					
48	L & T CR	M	14.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	20	Type:	R	Area:	4800.00 SqFt	PCI:	79		
Sample Comments:									
48	L & T CR	L	262.00	Ft					
57	WEATHERING	L	2880.00	SqFt					
Sample Number:	27	Type:	R	Area:	4800.00 SqFt	PCI:	80		
Sample Comments:									
48	L & T CR	L	240.00	Ft					
57	WEATHERING	L	4800.00	SqFt					
Sample Number:	32	Type:	R	Area:	4800.00 SqFt	PCI:	80		
Sample Comments:									
48	L & T CR	L	240.00	Ft					
57	WEATHERING	L	2880.00	SqFt					
Sample Number:	39	Type:	R	Area:	3440.00 SqFt	PCI:	94		
Sample Comments:									
57	WEATHERING	L	3440.00	SqFt					

Network:	DLN	Name:	Dillon Airport						
Branch:	RW17	Name:	runway 17-35	Use:	RUNWAY	Area:	525,900 SqFt		
Section:	03	of 2	From:	RW 16-34 STA 10+00	To:	RW 16-34 STA 67+20	Last Const.: 9/20/1998		
Surface:	AC	Family:	DEFAULT	Zone:	DILL	Category:	D	Rank:	P
Area:	467,400 SqFt	Length:	5,720 Ft	Width:	75 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACM	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	9/20/1998	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	1/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Work Date:	1/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Last Insp. Date:	9/10/2021	TotalSamples:	95	Surveyed:	7				
Conditions:	PCI: 55								
Inspection Comments:									
Sample Number:	02	Type:	R	Area:	4875.00 SqFt	PCI:	53		
Sample Comments:									
41	ALLIGATOR CR	L	76.00	SqFt					
48	L & T CR	L	410.00	Ft					
48	L & T CR	M	15.00	Ft					
50	PATCHING	L	22.00	SqFt					
57	WEATHERING	L	4368.00	SqFt					
57	WEATHERING	M	485.00	SqFt					
Sample Number:	16	Type:	R	Area:	4875.00 SqFt	PCI:	54		
Sample Comments:									
48	L & T CR	L	592.00	Ft					
48	L & T CR	M	40.00	Ft					
53	RUTTING	L	40.00	SqFt					
57	WEATHERING	L	4387.00	SqFt					
57	WEATHERING	M	488.00	SqFt					
Sample Number:	30	Type:	R	Area:	4875.00 SqFt	PCI:	54		
Sample Comments:									
48	L & T CR	L	587.00	Ft					
48	L & T CR	M	100.00	Ft					
53	RUTTING	L	20.00	SqFt					
57	WEATHERING	L	4387.00	SqFt					
57	WEATHERING	M	488.00	SqFt					
Sample Number:	44	Type:	R	Area:	4875.00 SqFt	PCI:	59		
Sample Comments:									
48	L & T CR	L	586.00	Ft					
48	L & T CR	M	100.00	Ft					
57	WEATHERING	L	4387.00	SqFt					
57	WEATHERING	M	488.00	SqFt					
Sample Number:	58	Type:	R	Area:	4875.00 SqFt	PCI:	58		
Sample Comments:									
48	L & T CR	L	635.00	Ft					
48	L & T CR	M	99.00	Ft					
57	WEATHERING	L	4387.00	SqFt					
57	WEATHERING	M	488.00	SqFt					
Sample Number:	72	Type:	R	Area:	4875.00 SqFt	PCI:	59		
Sample Comments:									
48	L & T CR	L	579.00	Ft					
48	L & T CR	M	77.00	Ft					
57	WEATHERING	L	4387.00	SqFt					
57	WEATHERING	M	488.00	SqFt					

Sample Number: 86

Type: R

Area: 4875.00 SqFt

PCI: 49

Sample Comments:

41	ALLIGATOR CR	L	6.00	SqFt
48	L & T CR	L	599.00	Ft
48	L & T CR	M	72.00	Ft
53	RUTTING	L	30.00	SqFt
57	WEATHERING	L	4387.00	SqFt
57	WEATHERING	M	488.00	SqFt

Network:	DLN	Name:	Dillon Airport						
Branch:	RW17	Name:	runway 17-35	Use:	RUNWAY	Area:	525,900 SqFt		
Section:	04	of 2	From:	RW 16-34 STA 67+20	To:	RW 16-34 STA 75+00	Last Const.:	9/29/1998	
Surface:	AC	Family:	DEFAULT	Zone:	DILL	Category:	D	Rank:	P
Area:	58,500 SqFt	Length:	780 Ft	Width:	75 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	ACM	Grade:	0	Lanes:	0			
Section Comments:									
Work Date:	9/29/1998	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	1/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Work Date:	1/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Last Insp. Date:	9/10/2021	TotalSamples:	12	Surveyed:	5				
Conditions:	PCI: 56								
Inspection Comments:									
Sample Number:	01	Type:	R	Area:	4875.00 SqFt	PCI:	55		
Sample Comments:									
42	BLEEDING	N	24.00	SqFt					
48	L & T CR	L	643.00	Ft					
48	L & T CR	M	72.00	Ft					
57	WEATHERING	L	4387.00	SqFt					
57	WEATHERING	M	488.00	SqFt					
Sample Number:	03	Type:	R	Area:	4875.00 SqFt	PCI:	58		
Sample Comments:									
48	L & T CR	L	621.00	Ft					
48	L & T CR	M	69.00	Ft					
57	WEATHERING	L	4144.00	SqFt					
57	WEATHERING	M	731.00	SqFt					
Sample Number:	05	Type:	R	Area:	4875.00 SqFt	PCI:	63		
Sample Comments:									
45	DEPRESSION	H	3.00	SqFt					
48	L & T CR	L	281.00	Ft					
48	L & T CR	M	108.00	Ft					
57	WEATHERING	L	4387.00	SqFt					
57	WEATHERING	M	488.00	SqFt					
Sample Number:	07	Type:	R	Area:	4875.00 SqFt	PCI:	52		
Sample Comments:									
41	ALLIGATOR CR	L	4.00	SqFt					
48	L & T CR	L	480.00	Ft					
48	L & T CR	M	121.00	Ft					
48	L & T CR	H	14.00	Ft					
57	WEATHERING	L	4387.00	SqFt					
57	WEATHERING	M	488.00	SqFt					
Sample Number:	09	Type:	R	Area:	4875.00 SqFt	PCI:	53		
Sample Comments:									
41	ALLIGATOR CR	L	30.00	SqFt					
48	L & T CR	L	432.00	Ft					
48	L & T CR	M	63.00	Ft					
53	RUTTING	L	55.00	SqFt					
57	WEATHERING	L	4387.00	SqFt					
57	WEATHERING	M	488.00	SqFt					

Network: DLN **Name:** Dillon Airport

Branch: TW **Name:** Taxiway **Use:** TAXIWAY **Area:** 288,648 SqFt

Section: 02 of 4 **From:** Apron A-3 **To:** HANGARS **Last Const.:** 9/30/1994

Surface: AC **Family:** DEFAULT **Zone:** DILL **Category:** D **Rank:** P

Area: 16,510 SqFt **Length:** 610 Ft **Width:** 25 Ft

Slabs: **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

Shoulder: **Street Type:** ACM **Grade:** 0 **Lanes:** 0

Section Comments:

Work Date: 9/30/1994 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

Work Date: 1/1/2019 **Work Type:** Crack Sealing - AC **Code:** CS-AC **Is Major M&R:** False

Work Date: 1/1/2019 **Work Type:** Surface Seal **Code:** SS-LO **Is Major M&R:** False

Last Insp. Date: 9/10/2021 **TotalSamples:** 4 **Surveyed:** 3

Conditions: PCI: 77

Inspection Comments:

Sample Number: 01 **Type:** R **Area:** 4000.00 SqFt **PCI:** 75

Sample Comments:

48 L & T CR L 141.00 Ft

48 L & T CR M 5.00 Ft

57 WEATHERING L 3600.00 SqFt

57 WEATHERING M 400.00 SqFt

Sample Number: 02 **Type:** R **Area:** 4000.00 SqFt **PCI:** 77

Sample Comments:

48 L & T CR L 98.00 Ft

48 L & T CR M 2.00 Ft

57 WEATHERING L 3600.00 SqFt

57 WEATHERING M 400.00 SqFt

Sample Number: 04 **Type:** R **Area:** 3625.00 SqFt **PCI:** 80

Sample Comments:

48 L & T CR L 113.00 Ft

57 WEATHERING L 3263.00 SqFt

57 WEATHERING M 362.00 SqFt

Network:	DLN	Name:	Dillon Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	288,648 SqFt		
Section:	03	of 4	From:	RW 16-34 PARALLEL TW	To:	AND MID-FIELD CONNECTOR	Last Const.: 9/20/1998		
Surface:	AC	Family:	DEFAULT	Zone:	DILL	Category:	D	Rank:	P
Area:	212,275 SqFt	Length:	6,065 Ft	Width:	35 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACM	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	9/20/1998	Work Type: New Construction - Initial			Code:	NU-IN	Is Major M&R: True		
Work Date:	1/1/2019	Work Type: Surface Seal			Code:	SS-LO	Is Major M&R: False		
Work Date:	1/1/2019	Work Type: Crack Sealing - AC			Code:	CS-AC	Is Major M&R: False		
Last Insp. Date:	9/10/2021	TotalSamples:	43	Surveyed:	6				
Conditions:	PCI: 52								
Inspection Comments:									
Sample Number:	02	Type:	R	Area:	4900.00 SqFt	PCI:	62		
Sample Comments:									
41	ALLIGATOR CR	L	8.00	SqFt					
48	L & T CR	L	450.00	Ft					
48	L & T CR	M	67.00	Ft					
48	L & T CR	H	5.00	Ft					
57	WEATHERING	L	4900.00	SqFt					
Sample Number:	08	Type:	R	Area:	4900.00 SqFt	PCI:	56		
Sample Comments:									
48	L & T CR	L	506.00	Ft					
48	L & T CR	M	87.00	Ft					
53	RUTTING	L	46.00	SqFt					
57	WEATHERING	L	4410.00	SqFt					
57	WEATHERING	M	490.00	SqFt					
Sample Number:	14	Type:	R	Area:	4900.00 SqFt	PCI:	72		
Sample Comments:									
48	L & T CR	L	240.00	Ft					
48	L & T CR	M	124.00	Ft					
57	WEATHERING	L	4900.00	SqFt					
Sample Number:	20	Type:	R	Area:	4900.00 SqFt	PCI:	63		
Sample Comments:									
41	ALLIGATOR CR	L	5.00	SqFt					
45	DEPRESSION	L	16.00	SqFt					
48	L & T CR	L	243.00	Ft					
48	L & T CR	M	52.00	Ft					
57	WEATHERING	L	4410.00	SqFt					
57	WEATHERING	M	490.00	SqFt					
Sample Number:	28	Type:	R	Area:	4900.00 SqFt	PCI:	16		
Sample Comments:									
41	ALLIGATOR CR	L	7.00	SqFt					
48	L & T CR	L	288.00	Ft					
48	L & T CR	M	99.00	Ft					
53	RUTTING	L	600.00	SqFt					
53	RUTTING	M	592.00	SqFt					
53	RUTTING	H	348.00	SqFt					
57	WEATHERING	L	4410.00	SqFt					
57	WEATHERING	M	490.00	SqFt					
Sample Number:	36	Type:	R	Area:	4900.00 SqFt	PCI:	43		
Sample Comments:									
48	L & T CR	L	268.00	Ft					

48	L & T CR	M	49.00	Ft
53	RUTTING	L	1400.00	SqFt
57	WEATHERING	L	4410.00	SqFt
57	WEATHERING	M	490.00	SqFt

Network:	DLN	Name:	Dillon Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	288,648 SqFt		
Section:	04	of 4	From:	R-2	To:	HANGARS	Last Const.:	8/1/2002	
Surface:	AC	Family:	DEFAULT	Zone:	DILL	Category:	D	Rank:	P
Area:	26,575 SqFt	Length:	1,063 Ft	Width:	25 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	ACM	Grade:	0	Lanes:	0			
Section Comments:									
Work Date:	8/1/2002	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	1/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Work Date:	1/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Last Insp. Date:	9/10/2021	TotalSamples:	5	Surveyed:	3				
Conditions:	PCI: 80								
Inspection Comments:									
Sample Number:	02	Type:	R	Area:	5000.00 SqFt	PCI:	81		
Sample Comments:									
48	L & T CR	L	235.00 Ft						
57	WEATHERING	L	5000.00 SqFt						
Sample Number:	03	Type:	R	Area:	5000.00 SqFt	PCI:	78		
Sample Comments:									
48	L & T CR	L	202.00 Ft						
48	L & T CR	M	2.00 Ft						
57	WEATHERING	L	5000.00 SqFt						
Sample Number:	04	Type:	R	Area:	5000.00 SqFt	PCI:	82		
Sample Comments:									
48	L & T CR	L	219.00 Ft						
57	WEATHERING	L	5000.00 SqFt						

Network:	DLN	Name:	Dillon Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	288,648 SqFt		
Section:	05	of 4	From:	North end of T-3	To:	Southern end of A-3	Last Const.: 8/1/2009		
Surface:	AC	Family:	DEFAULT	Zone:	DILL	Category:	D	Rank:	P
Area:	33,288 SqFt	Length:	912 Ft	Width:	36 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	ACM	Grade:	0	Lanes:	0			
Section Comments:									
Work Date:	8/1/2009	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Work Date:	1/1/2019	Work Type:	Crack Sealing - AC		Code:	CS-AC	Is Major M&R:	False	
Work Date:	1/1/2019	Work Type:	Surface Seal		Code:	SS-LO	Is Major M&R:	False	
Last Insp. Date:	9/10/2021	TotalSamples:	8	Surveyed:	4				
Conditions:	PCI: 82								
Inspection Comments:									
Sample Number:	02	Type:	R	Area:	4445.00 SqFt	PCI:	74		
Sample Comments:									
48	L & T CR	L	103.00	Ft					
53	RUTTING	L	48.00	SqFt					
57	WEATHERING	L	4445.00	SqFt					
Sample Number:	04	Type:	R	Area:	4445.00 SqFt	PCI:	87		
Sample Comments:									
48	L & T CR	L	11.00	Ft					
57	WEATHERING	L	4223.00	SqFt					
57	WEATHERING	M	222.00	SqFt					
Sample Number:	06	Type:	R	Area:	3939.00 SqFt	PCI:	82		
Sample Comments:									
48	L & T CR	L	109.00	Ft					
57	WEATHERING	L	3742.00	SqFt					
57	WEATHERING	M	197.00	SqFt					
Sample Number:	08	Type:	R	Area:	3535.00 SqFt	PCI:	86		
Sample Comments:									
48	L & T CR	L	19.00	Ft					
57	WEATHERING	L	3358.00	SqFt					
57	WEATHERING	M	177.00	SqFt					