


This document, together with the concepts and designs presented herein, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kinney-Horn and Associates, Inc. shall be without liability to Kinney-Horn and Associates, Inc.



LEGEND

—	BRANCH IDENTIFIER
RW01:10	SECTION IDENTIFIER
—	SECTION BOUNDARY
Dark Green	PCI 86-100 GOOD
Light Green	PCI 71-85 SATISFACTORY
Yellow	PCI 56-70 FAIR
Orange	PCI 41-55 POOR
Pink	PCI 26-40 VERY POOR
Red	PCI 11-25 SERIOUS
Grey	PCI 0-10 FAILED

CURRENT 2021 PAVEMENT CONDITION INDEX

Branch ID	Section ID	Branch Name	Surface Type	Section Area (SF)	Approx. Age at Inspection	Last Major Work Date	Last Inspection Date	Pavement Condition Index	PCI Category
AP	03	Apron	AC	40,638	3.4	6/28/2018	9/6/2021	97	Good
AP	11	Apron	AC	199,475	23.3	8/1/1998	9/6/2021	52	Poor
RW18	11	Runway 18-36	AC	315,000	23.3	8/1/1998	9/6/2021	47	Poor
TW	11	Taxiway	AC	170,450	22.3	8/1/1999	9/6/2021	59	Fair
TW	12	Taxiway	AC	32,925	22.3	8/1/1999	9/6/2021	56	Fair
TW	14	Taxiway	AC	23,875	18.3	8/1/2003	9/6/2021	84	Satisfactory

AIRFIELD PAVEMENT WORK HISTORY

1. FAAP-01, 1966
2. AIP-001-1983, OVERLAY AND EXTEND RUNWAY 18/36; CONSTRUCT TURNAROUNDS; OVERLAY AND EXPAND CONNECTING TAXIWAY AND APRON.
3. AIP-002-1998, REHABILITATE AND WIDEN RUNWAY; REHABILITATE CONNECTING TAXIWAY AND PORTION OF APRON.
4. AIP-003-1999, CONSTRUCT PARALLEL, CONNECTING AND HANGAR ACCESS TAXIWAYS (TW:11, TW:12).
5. AIP-004, 2003, CONSTRUCT HANGAR TAXIWAY E (TW:14); CRACK SEAL, FOG SEAL, AND REMARK ALL PAVEMENTS.
6. AIP-005-2007, CONSTRUCT SELF-FUELING APRON (AP:03).
7. AIP-007-2015, CRACK SEAL, SEAL COAT, AND REMARK ALL PAVEMENTS [INSPECTED PRIOR TO PROJECT].
8. AIP-009-2017, RECONSTRUCT EXISTING APRON (AP:03).

Runway



RW18-11-15: Swelling



RW18-11-34: Patching



RW18-11-55: Weathering



RW18-11-63: Depression

Taxiway



TW11-26: L&T Cracking



TW12-07: Overview

Apron



AP03-04: Weathering



AP11-21: Overview



AP11-34: Alligator Cracking



AP11-34: Swelling

Re-Inspection Report

MDT SASP 2021

Generated Date 12/6/2021

Page 1 of 7

Network: 8S1 Name: Polson Airport

Branch: AP Name: Apron Use: APRON Area: 240,113 SqFt

Section: 03 of 2 From: A-11 To: HANGARS Last Const.: 6/28/2018

Surface: AC Family: DEFAULT Zone: Category: Rank: P

Area: 40,638 SqFt Length: 260 Ft Width: 206 Ft

Slabs: Slab Length: Ft Slab Width: Ft Joint Length: Ft

Shoulder: Street Type: Grade: 0 Lanes: 0

Section Comments:

Work Date: 6/28/2018 Work Type: New Construction - AC Code: NC-AC Is Major M&R: True

Last Insp. Date: 9/6/2021 TotalSamples: 9 Surveyed: 4

Conditions: PCI: 97

Inspection Comments:

Sample Number: 01 Type: R Area: 4887.00 SqFt PCI: 97

Sample Comments:

57 WEATHERING L 1250.00 SqFt

Sample Number: 03 Type: R Area: 4900.00 SqFt PCI: 97

Sample Comments:

57 WEATHERING L 1250.00 SqFt

Sample Number: 04 Type: R Area: 4429.00 SqFt PCI: 96

Sample Comments:

57 WEATHERING L 1250.00 SqFt

Sample Number: 06 Type: R Area: 4900.00 SqFt PCI: 97

Sample Comments:

57 WEATHERING L 1250.00 SqFt

Network:	8S1	Name:	Polson Airport				
Branch:	AP	Name:	Apron	Use:	APRON	Area:	240,113 SqFt
Section:	11	of 2	From:	ENTIRE APRON	To:		Last Const.: 8/1/1998
Surface:	AC	Family:	DEFAULT	Zone:		Category:	D
Area:	199,475 SqFt	Length:	775 Ft	Width:	245 Ft	Rank:	P
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft
Shoulder:		Street Type:	ACN	Grade:	0	Lanes:	0
Section Comments:							
Work Date:	8/1/1998	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R: True
Last Insp. Date:	9/6/2021	TotalSamples:	40	Surveyed:	6		
Conditions:	PCI: 52						
Inspection Comments:							
Sample Number:	07	Type:	R	Area:	4900.00 SqFt	PCI:	59
Sample Comments:							
48	L & T CR	L	627.00	Ft			
48	L & T CR	M	7.00	Ft			
57	WEATHERING	L	4165.00	SqFt			
57	WEATHERING	M	735.00	SqFt			
Sample Number:	14	Type:	R	Area:	1900.00 SqFt	PCI:	45
Sample Comments:							
45	DEPRESSION	L	28.00	SqFt			
48	L & T CR	L	312.00	Ft			
48	L & T CR	M	10.00	Ft			
50	PATCHING	L	85.00	SqFt			
57	WEATHERING	L	881.00	SqFt			
57	WEATHERING	M	934.00	SqFt			
Sample Number:	21	Type:	R	Area:	4900.00 SqFt	PCI:	56
Sample Comments:							
48	L & T CR	L	724.00	Ft			
48	L & T CR	M	94.00	Ft			
57	WEATHERING	L	4165.00	SqFt			
57	WEATHERING	M	735.00	SqFt			
Sample Number:	27	Type:	R	Area:	4900.00 SqFt	PCI:	60
Sample Comments:							
48	L & T CR	L	543.00	Ft			
48	L & T CR	M	72.00	Ft			
57	WEATHERING	L	4165.00	SqFt			
57	WEATHERING	M	735.00	SqFt			
Sample Number:	34	Type:	R	Area:	5700.00 SqFt	PCI:	30
Sample Comments:							
41	ALLIGATOR CR	L	110.00	SqFt			
43	BLOCK CR	L	3423.00	SqFt			
45	DEPRESSION	L	39.00	SqFt			
52	RAVELING	L	1250.00	SqFt			
56	SWELLING	M	180.00	SqFt			
56	SWELLING	H	180.00	SqFt			
57	WEATHERING	L	3750.00	SqFt			
Sample Number:	35	Type:	R	Area:	4900.00 SqFt	PCI:	60
Sample Comments:							
48	L & T CR	L	570.00	Ft			
48	L & T CR	M	65.00	Ft			
57	WEATHERING	L	3920.00	SqFt			
57	WEATHERING	M	980.00	SqFt			

Network:	8S1		Name:	Polson Airport					
Branch:	RW18	Name:	Runway 18-36	Use:	RUNWAY	Area:	315,000 SqFt		
Section:	11	of 1	From:	STA 10+00	To:	STA 52+00	Last Const.:	8/1/1998	
Surface:	AC	Family:	DEFAULT	Zone:		Category:	D	Rank:	P
Area:	315,000 SqFt	Length:	4,200 Ft	Width:	75 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACM	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/1/1998	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Last Insp. Date:	9/6/2021	TotalSamples:	65	Surveyed:	8				
Conditions:	PCI: 47								
Inspection Comments:									
Sample Number:	05	Type:	R	Area:	4875.00 SqFt	PCI:	50		
Sample Comments:									
45	DEPRESSION	L	48.00	SqFt					
48	L & T CR	L	596.00	Ft					
48	L & T CR	M	26.00	Ft					
56	SWELLING	L	60.00	SqFt					
57	WEATHERING	L	3656.00	SqFt					
57	WEATHERING	M	1219.00	SqFt					
Sample Number:	15	Type:	R	Area:	4875.00 SqFt	PCI:	49		
Sample Comments:									
48	L & T CR	L	825.00	Ft					
48	L & T CR	M	18.00	Ft					
56	SWELLING	L	222.00	SqFt					
57	WEATHERING	L	3900.00	SqFt					
57	WEATHERING	M	975.00	SqFt					
Sample Number:	25	Type:	R	Area:	4875.00 SqFt	PCI:	54		
Sample Comments:									
48	L & T CR	L	733.00	Ft					
48	L & T CR	M	7.00	Ft					
56	SWELLING	L	54.00	SqFt					
57	WEATHERING	L	3900.00	SqFt					
57	WEATHERING	M	975.00	SqFt					
Sample Number:	34	Type:	A	Area:	4875.00 SqFt	PCI:	39		
Sample Comments:									
48	L & T CR	L	629.00	Ft					
48	L & T CR	M	12.00	Ft					
50	PATCHING	L	450.00	SqFt					
50	PATCHING	H	450.00	SqFt					
57	WEATHERING	M	820.00	SqFt					
Sample Number:	35	Type:	R	Area:	4875.00 SqFt	PCI:	54		
Sample Comments:									
48	L & T CR	L	858.00	Ft					
48	L & T CR	M	59.00	Ft					
57	WEATHERING	L	3900.00	SqFt					
57	WEATHERING	M	975.00	SqFt					
Sample Number:	45	Type:	R	Area:	4875.00 SqFt	PCI:	53		
Sample Comments:									
48	L & T CR	L	647.00	Ft					
48	L & T CR	M	86.00	Ft					
56	SWELLING	L	96.00	SqFt					
57	WEATHERING	L	3900.00	SqFt					
57	WEATHERING	M	975.00	SqFt					
Sample Number:	55	Type:	R	Area:	4875.00 SqFt	PCI:	54		
Sample Comments:									

48	L & T CR	L	578.00	Ft
48	L & T CR	M	30.00	Ft
56	SWELLING	L	130.00	SqFt
57	WEATHERING	L	3413.00	SqFt
57	WEATHERING	M	1462.00	SqFt

Sample Number: 63 **Type:** R **Area:** 4875.00 SqFt **PCI:** 16

Sample Comments:

45	DEPRESSION	L	1300.00	SqFt
45	DEPRESSION	M	1625.00	SqFt
48	L & T CR	L	1008.00	Ft
48	L & T CR	M	29.00	Ft
57	WEATHERING	L	3413.00	SqFt
57	WEATHERING	M	1462.00	SqFt

Network:	8S1	Name:	Polson Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	227,250 SqFt		
Section:	11	of 3	From:	R-11 PARALLEL TW	To:	A-11	Last Const.:	8/1/1999	
Surface:	AC	Family:	DEFAULT	Zone:		Category:	D	Rank:	P
Area:	170,450 SqFt	Length:	4,870 Ft	Width:	35 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACM	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/1/1999	Work Type:			New Construction - Initial	Code:	NU-IN	Is Major M&R:	True
Last Insp. Date:	9/6/2021	TotalSamples:	35	Surveyed:	5				
Conditions:	PCI: 59								
Inspection Comments:									
Sample Number:	05	Type:	R	Area:	5075.00 SqFt	PCI:	59		
Sample Comments:									
48	L & T CR	L	628.00	Ft					
48	L & T CR	M	32.00	Ft					
57	WEATHERING	L	4060.00	SqFt					
57	WEATHERING	M	1015.00	SqFt					
Sample Number:	12	Type:	R	Area:	5075.00 SqFt	PCI:	57		
Sample Comments:									
48	L & T CR	L	724.00	Ft					
48	L & T CR	M	44.00	Ft					
57	WEATHERING	L	4060.00	SqFt					
57	WEATHERING	M	1015.00	SqFt					
Sample Number:	19	Type:	R	Area:	5075.00 SqFt	PCI:	60		
Sample Comments:									
45	DEPRESSION	L	2.00	SqFt					
48	L & T CR	L	554.00	Ft					
48	L & T CR	M	18.00	Ft					
57	WEATHERING	L	4060.00	SqFt					
57	WEATHERING	M	1015.00	SqFt					
Sample Number:	26	Type:	R	Area:	5075.00 SqFt	PCI:	63		
Sample Comments:									
48	L & T CR	L	458.00	Ft					
48	L & T CR	M	12.00	Ft					
57	WEATHERING	L	4060.00	SqFt					
57	WEATHERING	M	1015.00	SqFt					
Sample Number:	33	Type:	R	Area:	3238.00 SqFt	PCI:	56		
Sample Comments:									
48	L & T CR	L	536.00	Ft					
48	L & T CR	M	4.00	Ft					
57	WEATHERING	L	2590.00	SqFt					
57	WEATHERING	M	648.00	SqFt					

Network:	8S1	Name:	Polson Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	227,250 SqFt		
Section:	12	of 3	From:	R-11	To:	HANGARS	Last Const.:	8/1/1999	
Surface:	AC	Family:	DEFAULT	Zone:		Category:	D	Rank:	P
Area:	32,925 SqFt	Length:	1,317 Ft	Width:	25 Ft				
Slabs:		Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft		
Shoulder:		Street Type:	ACM	Grade:	0	Lanes:	0		
Section Comments:									
Work Date:	8/1/1999	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Last Insp. Date:	9/6/2021	TotalSamples:	9	Surveyed:	4				
Conditions:	PCI: 56								
Inspection Comments:									
Sample Number:	02	Type:	R	Area:	3875.00 SqFt	PCI:	57		
Sample Comments:									
48	L & T CR	L	547.00	Ft					
48	L & T CR	M	43.00	Ft					
57	WEATHERING	L	3100.00	SqFt					
57	WEATHERING	M	775.00	SqFt					
Sample Number:	05	Type:	R	Area:	3625.00 SqFt	PCI:	59		
Sample Comments:									
45	DEPRESSION	L	8.00	SqFt					
48	L & T CR	L	596.00	Ft					
57	WEATHERING	L	2900.00	SqFt					
57	WEATHERING	M	725.00	SqFt					
Sample Number:	07	Type:	R	Area:	4206.00 SqFt	PCI:	59		
Sample Comments:									
48	L & T CR	L	507.00	Ft					
48	L & T CR	M	69.00	Ft					
57	WEATHERING	L	2900.00	SqFt					
57	WEATHERING	M	725.00	SqFt					
Sample Number:	08	Type:	R	Area:	3625.00 SqFt	PCI:	49		
Sample Comments:									
45	DEPRESSION	L	20.00	SqFt					
48	L & T CR	L	700.00	Ft					
48	L & T CR	M	25.00	Ft					
57	WEATHERING	L	2900.00	SqFt					
57	WEATHERING	M	725.00	SqFt					

Network:	8S1	Name:	Polson Airport						
Branch:	TW	Name:	Taxiway	Use:	TAXIWAY	Area:	227,250 SqFt		
Section:	14	of 3	From:	T-12	To:	HANGARS	Last Const.:	8/1/2003	
Surface:	AC	Family:	DEFAULT	Zone:	POLS	Category:	D	Rank:	P
Area:	23,875 SqFt	Length:	955 Ft	Width:	25 Ft				
Slabs:	Slab Length:	Ft	Slab Width:	Ft	Joint Length:	Ft			
Shoulder:	Street Type:	ACM	Grade:	0	Lanes:	0			
Section Comments:									
Work Date:	8/1/2003	Work Type:	New Construction - Initial		Code:	NU-IN	Is Major M&R:	True	
Last Insp. Date:	9/6/2021	TotalSamples:	5	Surveyed:	3				
Conditions:	PCI: 84								
Inspection Comments:									
Sample Number:	01	Type:	R	Area:	4879.00 SqFt	PCI:	67		
Sample Comments:									
48	L & T CR	L	80.00	Ft					
50	PATCHING	L	891.00	SqFt					
57	WEATHERING	L	3690.00	SqFt					
57	WEATHERING	M	194.00	SqFt					
Sample Number:	03	Type:	R	Area:	4732.00 SqFt	PCI:	91		
Sample Comments:									
57	WEATHERING	L	4536.00	SqFt					
57	WEATHERING	M	239.00	SqFt					
Sample Number:	05	Type:	R	Area:	4732.00 SqFt	PCI:	94		
Sample Comments:									
57	WEATHERING	L	4732.00	SqFt					