


Plotted By: Lecky, Chance. Sheet: Sakzha - Layout PCI - November 02, 2021 09:46:18am K:\ORL\_Aviation\249025001 - MDT 2021 SAGS PCI Update\CAD\Airports\955 - Three Forks Airport\Exhibits\955 - PCI Exhibit.dwg  
 This document, together with the concepts and designs presented herein, is intended only for the specific purpose and client for which it was prepared. Reuse of and improper reliance on this document without written authorization and adaptation by Kinney-Horn and Associates, Inc. will be without liability to Kinney-Horn and Associates, Inc.



**CURRENT 2021 PAVEMENT CONDITION INDEX**

Branch ID	Section ID	Branch Name	Surface Type	Section Area (SF)	Approx. Age at Inspection	Last Major Work Date	Last Inspection Date	Pavement Condition Index	PCI Category
AP	01	Apron	AC	63,800	21.1	10/1/2000	8/16/2021	66	Fair
AP	02	Apron	PCC	5,400	35.2	8/1/1986	8/16/2021	54	Poor
RW03	01	Runway 03-21	AC	246,000	21.2	8/1/2000	8/16/2021	70	Fair
RW03	02	Runway 03-21	AC	60,000	21.2	8/1/2000	8/16/2021	64	Fair
TW	01	Taxiway	AC	12,975	21.2	8/1/2000	8/16/2021	62	Fair
TW	02	Taxiway	AC	74,150	21.2	8/1/2000	8/16/2021	77	Satisfactory
TW	03	Taxiway	AC	33,300	21.2	8/1/2000	8/16/2021	65	Fair
TW	04	Taxiway	AC	70,344	21.2	8/1/2000	8/16/2021	53	Poor
TW	05	Taxiway	AC	29,847	7	11/7/2014	8/16/2021	87	Good

**AIRFIELD PAVEMENT WORK HISTORY**

1. AIP-001-1986, ALL PAVEMENTS CONSTRUCTED.
2. AIP-002-1993, CONSTRUCT RUNWAY EXTENSION (RW03:02) AND PARTIAL PARALLEL TAXIWAY (TW:02).
3. AIP-003-2000, OVERLAY RUNWAY (RW03:01, RW03:02), APRON (AP:01), AND TAXIWAYS (TW:01, TW:02, TW:03); RECONSTRUCT TAXIWAY (TW:04).
4. AIP-007-2011, CRACK SEAL, FOG SEAL, AND REMARK ALL PAVEMENTS.
5. AIP-008-2014, CONSTRUCT TAXIWAY (TW:05).
6. AIP-011-2017, CRACK SEAL, SURFACE SEAL, AND REMARK ALL PAVEMENTS.

**MONTANA AVIATION SYSTEM PLAN**  
 2021 PAVEMENT CONDITION INDEX  
 PREPARED FOR  
 Montana Department of Transportation  
 Division of Aeronautics



Pavement Condition Index Map  
 9S5 - THREE FORKS AIRPORT

Runway



*RW03-01-21: Slippage Cracking*



*RW03-02-07: L&T Cracking*



Taxiway



*TW01-03: Slippage Cracking*



*TW03-07: Depression*



Apron



*AP01-03: L&T Cracking*



*AP01-12: Oil Spillage*

## Re-Inspection Report

MDT SASP 2021

Generated Date 12/16/2021

Page 1 of 9

**Network:** 9S5 **Name:** Three Forks Airport

**Branch:** AP **Name:** Apron **Use:** APRON **Area:** 69,200 SqFt

**Section:** 01 of 2 **From:** ENTIRE ASPHALT APRON **To:** **Last Const.:** 10/1/2000

**Surface:** AC **Family:** DEFAULT **Zone:** 3FOR **Category:** E **Rank:** P

**Area:** 63,800 SqFt **Length:** 360 Ft **Width:** 180 Ft

**Slabs:** **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

**Shoulder:** **Street Type:** ACN **Grade:** 0 **Lanes:** 0

**Section Comments:**

**Work Date:** 7/31/1986 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

**Work Date:** 10/1/2000 **Work Type:** Overlay - AC Thin **Code:** OL-AT **Is Major M&R:** True

**Work Date:** 7/1/2017 **Work Type:** Surface Seal **Code:** SS-LO **Is Major M&R:** False

**Work Date:** 7/1/2017 **Work Type:** Crack Sealing - AC **Code:** CS-AC **Is Major M&R:** False

**Last Insp. Date:** 8/16/2021 **Total Samples:** 14 **Surveyed:** 5

**Conditions:** PCI: 66

**Inspection Comments:**

**Sample Number:** 03 **Type:** R **Area:** 4500.00 SqFt **PCI:** 68

**Sample Comments:**

48	L & T CR	L	201.00	Ft
48	L & T CR	M	100.00	Ft
52	RAVELING	L	450.00	SqFt
57	WEATHERING	L	4050.00	SqFt

**Sample Number:** 06 **Type:** R **Area:** 4500.00 SqFt **PCI:** 73

**Sample Comments:**

48	L & T CR	L	286.00	Ft
52	RAVELING	L	225.00	SqFt
57	WEATHERING	L	4275.00	SqFt

**Sample Number:** 09 **Type:** R **Area:** 4500.00 SqFt **PCI:** 68

**Sample Comments:**

48	L & T CR	L	178.00	Ft
48	L & T CR	M	25.00	Ft
52	RAVELING	L	450.00	SqFt
55	SLIPPAGE CR	N	30.00	SqFt
57	WEATHERING	L	4050.00	SqFt

**Sample Number:** 12 **Type:** R **Area:** 4500.00 SqFt **PCI:** 59

**Sample Comments:**

48	L & T CR	L	321.00	Ft
48	L & T CR	M	50.00	Ft
49	OIL SPILLAGE	N	6.00	SqFt
52	RAVELING	L	450.00	SqFt
55	SLIPPAGE CR	N	18.00	SqFt
57	WEATHERING	L	4050.00	SqFt

**Sample Number:** 13 **Type:** R **Area:** 4550.00 SqFt **PCI:** 61

**Sample Comments:**

48	L & T CR	L	331.00	Ft
48	L & T CR	M	50.00	Ft
52	RAVELING	L	455.00	SqFt
55	SLIPPAGE CR	N	44.00	SqFt
57	WEATHERING	L	4095.00	SqFt

---

**Network:** 9S5 **Name:** Three Forks Airport

---

**Branch:** AP **Name:** Apron **Use:** APRON **Area:** 69,200 SqFt

---

**Section:** 02 of 2 **From:** PCC WASHING STATION **To:** **Last Const.:** 8/1/1986

**Surface:** PCC **Family:** DEFAULT **Zone:** 3FOR **Category:** P **Rank:** P

**Area:** 5,400 SqFt **Length:** 90 Ft **Width:** 60 Ft

**Slabs:** 12 **Slab Length:** 23 Ft **Slab Width:** 20 Ft **Joint Length:** 360 Ft

**Shoulder:** **Street Type:** PCA **Grade:** 0 **Lanes:** 0

**Section Comments:**

---

**Work Date:** 8/1/1986 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

---

**Last Insp. Date:** 8/16/2021 **TotalSamples:** 1 **Surveyed:** 1

**Conditions:** PCI: 54

**Inspection Comments:**

---

**Sample Number:** 01 **Type:** R **Area:** 12.00 Slabs **PCI:** 54

---

**Sample Comments:**

63	LINEAR CR	L	4.00	Slabs
65	JT SEAL DMG	M	12.00	Slabs
66	SMALL PATCH	L	1.00	Slabs
72	SHAT. SLAB	L	2.00	Slabs
73	SHRINKAGE CR	N	3.00	Slabs
74	JOINT SPALL	L	1.00	Slabs

<b>Network:</b>	9S5	<b>Name:</b>	Three Forks Airport						
<b>Branch:</b>	RW03	<b>Name:</b>	Runway 03-21	<b>Use:</b>	RUNWAY	<b>Area:</b>	306,000 SqFt		
<b>Section:</b>	01	of	2	<b>From:</b>	RWY 20-2 STA 0+00	<b>To:</b>	RWY 20-2 STA 41+00	<b>Last Const.:</b>	8/1/2000
<b>Surface:</b>	AC	<b>Family:</b>	DEFAULT	<b>Zone:</b>	3FOR	<b>Category:</b>	E	<b>Rank:</b>	P
<b>Area:</b>	246,000 SqFt	<b>Length:</b>	4,100 Ft	<b>Width:</b>	60 Ft				
<b>Slabs:</b>		<b>Slab Length:</b>	Ft	<b>Slab Width:</b>	Ft	<b>Joint Length:</b>	Ft		
<b>Shoulder:</b>		<b>Street Type:</b>	ACM	<b>Grade:</b>	0	<b>Lanes:</b>	0		
<b>Section Comments:</b>									
<b>Work Date:</b>	7/31/1986	<b>Work Type:</b> New Construction - Initial			<b>Code:</b>	NU-IN	<b>Is Major M&amp;R:</b> True		
<b>Work Date:</b>	8/1/2000	<b>Work Type:</b> Overlay - AC Thin			<b>Code:</b>	OL-AT	<b>Is Major M&amp;R:</b> True		
<b>Work Date:</b>	7/1/2017	<b>Work Type:</b> Surface Seal			<b>Code:</b>	SS-LO	<b>Is Major M&amp;R:</b> False		
<b>Work Date:</b>	7/1/2017	<b>Work Type:</b> Crack Sealing - AC			<b>Code:</b>	CS-AC	<b>Is Major M&amp;R:</b> False		
<b>Last Insp. Date:</b>	8/16/2021	<b>TotalSamples:</b>	51	<b>Surveyed:</b>	7				
<b>Conditions:</b>	PCI: 70								
<b>Inspection Comments:</b>									
<b>Sample Number:</b>	05	<b>Type:</b>	R	<b>Area:</b>	4800.00 SqFt	<b>PCI:</b>	71		
<b>Sample Comments:</b>									
48	L & T CR	L	336.00	Ft					
52	RAVELING	L	240.00	SqFt					
57	WEATHERING	L	4560.00	SqFt					
<b>Sample Number:</b>	13	<b>Type:</b>	R	<b>Area:</b>	4800.00 SqFt	<b>PCI:</b>	72		
<b>Sample Comments:</b>									
48	L & T CR	L	325.00	Ft					
52	RAVELING	L	240.00	SqFt					
57	WEATHERING	L	4560.00	SqFt					
<b>Sample Number:</b>	21	<b>Type:</b>	R	<b>Area:</b>	4800.00 SqFt	<b>PCI:</b>	65		
<b>Sample Comments:</b>									
48	L & T CR	L	363.00	Ft					
52	RAVELING	L	240.00	SqFt					
55	SLIPPAGE CR	N	96.00	SqFt					
57	WEATHERING	L	4560.00	SqFt					
<b>Sample Number:</b>	29	<b>Type:</b>	R	<b>Area:</b>	4800.00 SqFt	<b>PCI:</b>	74		
<b>Sample Comments:</b>									
48	L & T CR	L	277.00	Ft					
52	RAVELING	L	240.00	SqFt					
57	WEATHERING	L	4560.00	SqFt					
<b>Sample Number:</b>	37	<b>Type:</b>	R	<b>Area:</b>	4800.00 SqFt	<b>PCI:</b>	69		
<b>Sample Comments:</b>									
48	L & T CR	L	400.00	Ft					
52	RAVELING	L	240.00	SqFt					
57	WEATHERING	L	4560.00	SqFt					
<b>Sample Number:</b>	45	<b>Type:</b>	R	<b>Area:</b>	4800.00 SqFt	<b>PCI:</b>	70		
<b>Sample Comments:</b>									
48	L & T CR	L	369.00	Ft					
52	RAVELING	L	240.00	SqFt					
57	WEATHERING	L	4560.00	SqFt					
<b>Sample Number:</b>	51	<b>Type:</b>	R	<b>Area:</b>	4800.00 SqFt	<b>PCI:</b>	68		
<b>Sample Comments:</b>									
48	L & T CR	L	305.00	Ft					
52	RAVELING	L	240.00	SqFt					
55	SLIPPAGE CR	N	54.00	SqFt					
57	WEATHERING	L	4560.00	SqFt					

<b>Network:</b>	9S5	<b>Name:</b>	Three Forks Airport						
<b>Branch:</b>	RW03	<b>Name:</b>	Runway 03-21	<b>Use:</b>	RUNWAY	<b>Area:</b>	306,000 SqFt		
<b>Section:</b>	02	of 2	<b>From:</b>	RWY 20-2 STA 41+00	<b>To:</b>	RWY 20-2 STA51+00	<b>Last Const.:</b> 8/1/2000		
<b>Surface:</b>	AC	<b>Family:</b>	DEFAULT	<b>Zone:</b>	3FOR	<b>Category:</b>	E	<b>Rank:</b>	P
<b>Area:</b>	60,000 SqFt	<b>Length:</b>	1,000 Ft	<b>Width:</b>	60 Ft				
<b>Slabs:</b>		<b>Slab Length:</b>	Ft	<b>Slab Width:</b>	Ft	<b>Joint Length:</b>	Ft		
<b>Shoulder:</b>		<b>Street Type:</b>	ACM	<b>Grade:</b>	0	<b>Lanes:</b>	0		
<b>Section Comments:</b>									
<b>Work Date:</b>	8/31/1993	<b>Work Type:</b> New Construction - Initial			<b>Code:</b>	NU-IN	<b>Is Major M&amp;R:</b> True		
<b>Work Date:</b>	8/1/2000	<b>Work Type:</b> Overlay - AC Thin			<b>Code:</b>	OL-AT	<b>Is Major M&amp;R:</b> True		
<b>Work Date:</b>	7/1/2017	<b>Work Type:</b> Crack Sealing - AC			<b>Code:</b>	CS-AC	<b>Is Major M&amp;R:</b> False		
<b>Work Date:</b>	7/1/2017	<b>Work Type:</b> Surface Seal			<b>Code:</b>	SS-LO	<b>Is Major M&amp;R:</b> False		
<b>Last Insp. Date:</b>	8/16/2021	<b>TotalSamples:</b>	12	<b>Surveyed:</b>	5				
<b>Conditions:</b>	PCI: 64								
<b>Inspection Comments:</b>									
<b>Sample Number:</b>	01	<b>Type:</b>	R	<b>Area:</b>	4800.00 SqFt	<b>PCI:</b>	67		
<b>Sample Comments:</b>									
48	L & T CR	L	329.00	Ft					
52	RAVELING	L	240.00	SqFt					
55	SLIPPAGE CR	N	60.00	SqFt					
57	WEATHERING	L	4560.00	SqFt					
<b>Sample Number:</b>	04	<b>Type:</b>	R	<b>Area:</b>	4800.00 SqFt	<b>PCI:</b>	70		
<b>Sample Comments:</b>									
45	DEPRESSION	H	4.00	SqFt					
48	L & T CR	L	253.00	Ft					
52	RAVELING	L	240.00	SqFt					
57	WEATHERING	L	4560.00	SqFt					
<b>Sample Number:</b>	07	<b>Type:</b>	R	<b>Area:</b>	4800.00 SqFt	<b>PCI:</b>	53		
<b>Sample Comments:</b>									
48	L & T CR	L	220.00	Ft					
48	L & T CR	M	30.00	Ft					
52	RAVELING	L	240.00	SqFt					
55	SLIPPAGE CR	N	152.00	SqFt					
57	WEATHERING	L	4560.00	SqFt					
<b>Sample Number:</b>	10	<b>Type:</b>	R	<b>Area:</b>	4800.00 SqFt	<b>PCI:</b>	66		
<b>Sample Comments:</b>									
48	L & T CR	L	232.00	Ft					
48	L & T CR	M	40.00	Ft					
52	RAVELING	L	240.00	SqFt					
55	SLIPPAGE CR	N	63.00	SqFt					
57	WEATHERING	L	4560.00	SqFt					
<b>Sample Number:</b>	12	<b>Type:</b>	R	<b>Area:</b>	4800.00 SqFt	<b>PCI:</b>	65		
<b>Sample Comments:</b>									
48	L & T CR	L	245.00	Ft					
48	L & T CR	M	40.00	Ft					
52	RAVELING	L	240.00	SqFt					
55	SLIPPAGE CR	N	30.00	SqFt					
57	WEATHERING	L	4560.00	SqFt					



<b>Network:</b>	9S5	<b>Name:</b>	Three Forks Airport						
<b>Branch:</b>	TW	<b>Name:</b>	Taxiway	<b>Use:</b>	TAXIWAY	<b>Area:</b>	220,616 SqFt		
<b>Section:</b>	01	of	5	<b>From:</b>	RWY 20-2	<b>To:</b>	APRON, WASH STA., RUNUP	<b>Last Const.:</b>	8/1/2000
<b>Surface:</b>	AC	<b>Family:</b>	DEFAULT	<b>Zone:</b>	3FOR	<b>Category:</b>	E	<b>Rank:</b>	P
<b>Area:</b>	12,975 SqFt	<b>Length:</b>	260 Ft	<b>Width:</b>	50 Ft				
<b>Slabs:</b>		<b>Slab Length:</b>	Ft	<b>Slab Width:</b>	Ft	<b>Joint Length:</b>	Ft		
<b>Shoulder:</b>		<b>Street Type:</b>	ACM	<b>Grade:</b>	0	<b>Lanes:</b>	0		
<b>Section Comments:</b>									
<b>Work Date:</b>	7/31/1986	<b>Work Type:</b>	New Construction - Initial		<b>Code:</b>	NU-IN	<b>Is Major M&amp;R:</b>	True	
<b>Work Date:</b>	8/1/2000	<b>Work Type:</b>	Overlay - AC Thin		<b>Code:</b>	OL-AT	<b>Is Major M&amp;R:</b>	True	
<b>Work Date:</b>	7/1/2017	<b>Work Type:</b>	Surface Seal		<b>Code:</b>	SS-LO	<b>Is Major M&amp;R:</b>	False	
<b>Work Date:</b>	7/1/2017	<b>Work Type:</b>	Crack Sealing - AC		<b>Code:</b>	CS-AC	<b>Is Major M&amp;R:</b>	False	
<b>Last Insp. Date:</b>	8/16/2021	<b>TotalSamples:</b>	4		<b>Surveyed:</b>	3			
<b>Conditions:</b>	PCI: 62								
<b>Inspection Comments:</b>									
<b>Sample Number:</b>	02	<b>Type:</b>	R	<b>Area:</b>	2750.00 SqFt	<b>PCI:</b>	62		
<b>Sample Comments:</b>									
45	DEPRESSION	L	28.00	SqFt					
48	L & T CR	L	179.00	Ft					
52	RAVELING	L	138.00	SqFt					
55	SLIPPAGE CR	N	45.00	SqFt					
57	WEATHERING	L	2612.00	SqFt					
<b>Sample Number:</b>	03	<b>Type:</b>	R	<b>Area:</b>	3675.00 SqFt	<b>PCI:</b>	55		
<b>Sample Comments:</b>									
48	L & T CR	L	229.00	Ft					
52	RAVELING	L	368.00	SqFt					
55	SLIPPAGE CR	N	136.00	SqFt					
57	WEATHERING	L	3307.00	SqFt					
<b>Sample Number:</b>	04	<b>Type:</b>	R	<b>Area:</b>	3675.00 SqFt	<b>PCI:</b>	69		
<b>Sample Comments:</b>									
48	L & T CR	L	209.00	Ft					
52	RAVELING	L	368.00	SqFt					
55	SLIPPAGE CR	N	18.00	SqFt					
57	WEATHERING	L	3307.00	SqFt					

**Network:** 9S5 **Name:** Three Forks Airport

**Branch:** TW **Name:** Taxiway **Use:** TAXIWAY **Area:** 220,616 SqFt

**Section:** 02 of 5 **From:** PARALLEL TO RWY 20-2 **To:** **Last Const.:** 8/1/2000

**Surface:** AC **Family:** DEFAULT **Zone:** 3FOR **Category:** E **Rank:** P

**Area:** 74,150 SqFt **Length:** 1,483 Ft **Width:** 50 Ft

**Slabs:** **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

**Shoulder:** **Street Type:** ACM **Grade:** 0 **Lanes:** 0

**Section Comments:**

**Work Date:** 8/31/1993 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

**Work Date:** 8/1/2000 **Work Type:** Overlay - AC Thin **Code:** OL-AT **Is Major M&R:** True

**Work Date:** 7/1/2017 **Work Type:** Surface Seal **Code:** SS-LO **Is Major M&R:** False

**Work Date:** 7/1/2017 **Work Type:** Crack Sealing - AC **Code:** CS-AC **Is Major M&R:** False

**Last Insp. Date:** 8/16/2021 **TotalSamples:** 16 **Surveyed:** 5

**Conditions:** PCI: 77

**Inspection Comments:**

**Sample Number:** 02 **Type:** R **Area:** 3700.00 SqFt **PCI:** 54

**Sample Comments:**

48 L & T CR L 217.00 Ft  
52 RAVELING L 185.00 SqFt  
55 SLIPPAGE CR N 140.00 SqFt  
57 WEATHERING L 3515.00 SqFt

**Sample Number:** 06 **Type:** R **Area:** 5000.00 SqFt **PCI:** 83

**Sample Comments:**

48 L & T CR L 87.00 Ft  
52 RAVELING L 250.00 SqFt  
57 WEATHERING L 4750.00 SqFt

**Sample Number:** 10 **Type:** R **Area:** 5000.00 SqFt **PCI:** 83

**Sample Comments:**

48 L & T CR L 90.00 Ft  
52 RAVELING L 250.00 SqFt  
57 WEATHERING L 4750.00 SqFt

**Sample Number:** 14 **Type:** R **Area:** 5000.00 SqFt **PCI:** 80

**Sample Comments:**

48 L & T CR L 143.00 Ft  
52 RAVELING L 250.00 SqFt  
57 WEATHERING L 4750.00 SqFt

**Sample Number:** 16 **Type:** R **Area:** 5000.00 SqFt **PCI:** 77

**Sample Comments:**

48 L & T CR L 211.00 Ft  
52 RAVELING L 250.00 SqFt  
57 WEATHERING L 4750.00 SqFt

**Network:** 9S5 **Name:** Three Forks Airport

**Branch:** TW **Name:** Taxiway **Use:** TAXIWAY **Area:** 220,616 SqFt

**Section:** 03 of 5 **From:** A-1 **To:** T-2 **Last Const.:** 8/1/2000

**Surface:** AC **Family:** DEFAULT **Zone:** **Category:** E **Rank:** P

**Area:** 33,300 SqFt **Length:** 370 Ft **Width:** 90 Ft

**Slabs:** **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

**Shoulder:** **Street Type:** ACM **Grade:** 0 **Lanes:** 0

**Section Comments:**

**Work Date:** 8/1/1993 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

**Work Date:** 8/1/2000 **Work Type:** Overlay - AC Thin **Code:** OL-AT **Is Major M&R:** True

**Work Date:** 7/1/2017 **Work Type:** Surface Seal **Code:** SS-LO **Is Major M&R:** False

**Work Date:** 7/1/2017 **Work Type:** Crack Sealing - AC **Code:** CS-AC **Is Major M&R:** False

**Last Insp. Date:** 8/16/2021 **TotalSamples:** 8 **Surveyed:** 4

**Conditions:** PCI: 65

**Inspection Comments:**

**Sample Number:** 01 **Type:** R **Area:** 5400.00 SqFt **PCI:** 68

**Sample Comments:**

45 DEPRESSION L 14.00 SqFt  
48 L & T CR L 302.00 Ft  
48 L & T CR M 100.00 Ft  
52 RAVELING L 540.00 SqFt  
57 WEATHERING L 4860.00 SqFt

**Sample Number:** 03 **Type:** R **Area:** 5400.00 SqFt **PCI:** 61

**Sample Comments:**

45 DEPRESSION L 28.00 SqFt  
48 L & T CR L 300.00 Ft  
48 L & T CR M 85.00 Ft  
52 RAVELING L 540.00 SqFt  
55 SLIPPAGE CR N 33.00 SqFt  
57 WEATHERING L 4860.00 SqFt

**Sample Number:** 05 **Type:** R **Area:** 5400.00 SqFt **PCI:** 69

**Sample Comments:**

48 L & T CR L 312.00 Ft  
48 L & T CR M 100.00 Ft  
52 RAVELING L 540.00 SqFt  
57 WEATHERING L 4860.00 SqFt

**Sample Number:** 07 **Type:** R **Area:** 4464.00 SqFt **PCI:** 61

**Sample Comments:**

45 DEPRESSION L 45.00 SqFt  
48 L & T CR L 332.00 Ft  
48 L & T CR M 100.00 Ft  
52 RAVELING L 223.00 SqFt  
57 WEATHERING L 4241.00 SqFt

**Network:** 9S5 **Name:** Three Forks Airport

**Branch:** TW **Name:** Taxiway **Use:** TAXIWAY **Area:** 220,616 SqFt

**Section:** 04 of 5 **From:** T-2 **To:** T-3 **Last Const.:** 8/1/2000

**Surface:** AC **Family:** DEFAULT **Zone:** 3FOR **Category:** E **Rank:** P

**Area:** 70,344 SqFt **Length:** 1,918 Ft **Width:** 37 Ft

**Slabs:** **Slab Length:** Ft **Slab Width:** Ft **Joint Length:** Ft

**Shoulder:** **Street Type:** ACM **Grade:** 0 **Lanes:** 0

**Section Comments:**

**Work Date:** 8/1/2000 **Work Type:** New Construction - Initial **Code:** NU-IN **Is Major M&R:** True

**Work Date:** 7/1/2017 **Work Type:** Surface Seal **Code:** SS-LO **Is Major M&R:** False

**Work Date:** 7/1/2017 **Work Type:** Crack Sealing - AC **Code:** CS-AC **Is Major M&R:** False

**Last Insp. Date:** 8/16/2021 **TotalSamples:** 16 **Surveyed:** 5

**Conditions:** PCI: 53

**Inspection Comments:**

**Sample Number:** 03 **Type:** R **Area:** 2448.00 SqFt **PCI:** 85

**Sample Comments:**

52 RAVELING L 245.00 SqFt

57 WEATHERING L 2203.00 SqFt

**Sample Number:** 07 **Type:** R **Area:** 4950.00 SqFt **PCI:** 46

**Sample Comments:**

48 L & T CR L 163.00 Ft

52 RAVELING L 248.00 SqFt

55 SLIPPAGE CR N 277.00 SqFt

57 WEATHERING L 4702.00 SqFt

**Sample Number:** 11 **Type:** R **Area:** 5063.00 SqFt **PCI:** 47

**Sample Comments:**

48 L & T CR L 53.00 Ft

52 RAVELING L 253.00 SqFt

55 SLIPPAGE CR N 280.00 SqFt

57 WEATHERING L 4810.00 SqFt

**Sample Number:** 15 **Type:** R **Area:** 2550.00 SqFt **PCI:** 22

**Sample Comments:**

45 DEPRESSION L 20.00 SqFt

48 L & T CR L 175.00 Ft

52 RAVELING L 128.00 SqFt

55 SLIPPAGE CR N 365.00 SqFt

57 WEATHERING L 2422.00 SqFt

**Sample Number:** 16 **Type:** R **Area:** 2550.00 SqFt **PCI:** 78

**Sample Comments:**

45 DEPRESSION L 9.00 SqFt

48 L & T CR L 34.00 Ft

52 RAVELING L 255.00 SqFt

57 WEATHERING L 2295.00 SqFt



<b>Network:</b>	9S5	<b>Name:</b>	Three Forks Airport						
<b>Branch:</b>	TW	<b>Name:</b>	Taxiway	<b>Use:</b>	TAXIWAY	<b>Area:</b>	220,616 SqFt		
<b>Section:</b>	05	of 5	<b>From:</b>	T-4	<b>To:</b>	HANGARS	<b>Last Const.:</b>	11/7/2014	
<b>Surface:</b>	AC	<b>Family:</b>	DEFAULT	<b>Zone:</b>		<b>Category:</b>		<b>Rank:</b>	P
<b>Area:</b>	29,847 SqFt	<b>Length:</b>	954 Ft	<b>Width:</b>	25 Ft				
<b>Slabs:</b>		<b>Slab Length:</b>	Ft	<b>Slab Width:</b>	Ft	<b>Joint Length:</b>	Ft		
<b>Shoulder:</b>		<b>Street Type:</b>		<b>Grade:</b>	0	<b>Lanes:</b>	0		
<b>Section Comments:</b>									
<b>Work Date:</b>	11/7/2014	<b>Work Type:</b>	New Construction - AC		<b>Code:</b>	NC-AC	<b>Is Major M&amp;R:</b>	True	
<b>Work Date:</b>	7/1/2017	<b>Work Type:</b>	Surface Seal		<b>Code:</b>	SS-LO	<b>Is Major M&amp;R:</b>	False	
<b>Work Date:</b>	7/1/2017	<b>Work Type:</b>	Crack Sealing - AC		<b>Code:</b>	CS-AC	<b>Is Major M&amp;R:</b>	False	
<b>Last Insp. Date:</b>	8/16/2021	<b>TotalSamples:</b>	6	<b>Surveyed:</b>	3				
<b>Conditions:</b>	PCI: 87								
<b>Inspection Comments:</b>									
<b>Sample Number:</b>	02	<b>Type:</b>	R	<b>Area:</b>	4600.00 SqFt	<b>PCI:</b>	89		
<b>Sample Comments:</b>									
48	L & T CR	L	40.00	Ft					
57	WEATHERING	L	4600.00	SqFt					
<b>Sample Number:</b>	04	<b>Type:</b>	R	<b>Area:</b>	4600.00 SqFt	<b>PCI:</b>	85		
<b>Sample Comments:</b>									
48	L & T CR	L	145.00	Ft					
57	WEATHERING	L	4600.00	SqFt					
<b>Sample Number:</b>	06	<b>Type:</b>	R	<b>Area:</b>	5000.00 SqFt	<b>PCI:</b>	86		
<b>Sample Comments:</b>									
48	L & T CR	L	126.00	Ft					
57	WEATHERING	L	5000.00	SqFt					